

Consumer Confidence Report

Annual Drinking Water Quality Report

COLLINSVILLE

ILL1194280

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by COLLINSVILLE is Ground Water

For more information regarding this report contact:

Name Doug Montgomery, Chief Operator

Phone 618-346-5219 ext. 112

Este informe contiene información muy importante sobre el agua que usted bebe. Tráúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to

Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 11 (60055)	GW	<u>Active</u>	
WELL 12 (01573)	GW	<u>Active</u>	
WELL 14 (01860)	GW	<u>Active</u>	550 feet away from City of Collinsville's Lime Sludge Lagoons
WELL 15 (01915)	GW	<u>Active</u>	
WELL 8 (60052)	GW	<u>Active</u>	
WELL 9 (60053)	GW	<u>Active</u>	

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 618-346-5219. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: COLLINSVILLE The Illinois EPA considers Collinsville's source water to be susceptible to IOC, VOC, and SOC contamination. This determination was made primarily based on the identification of potential sources and routes of contamination, land-use activities around the wells, available hydrogeologic data, and monitoring results. Materials reviewed included the Well Site Survey Report, published in 1990 and subsequent field surveys. During the surveys of the source water protection area, seven potential sources, routes, or possible problem sites were identified within the 400 foot minimum setback zones, the 1,000 foot Phase I Wellhead Protection Areas (WHPA), adopted maximum setback zones, and the Phase II WHPA. Two additional sites are located within 200 feet of the Phase II WHPA. Sampling performed to assess for pathogenic contamination (e.g., virus, total coliform, e-coli) has also demonstrated that the source water is not susceptible to these types of contaminants.

Source Water Protection Efforts:

The Environmental Protection Act provides minimum protection zones of 400 feet from Collinsville's wells. These minimum protection zones are regulated by the Environmental Protection Agency. To further reduce the potential risk of source water contamination, the community has adopted a maximum setback zone for wells #8, 9, 11, 12, 14, and 15 which is authorized by the IEPA and allows County and Municipal Officials the opportunity to provide additional source prohibitions up to 1000 feet from the wells. In addition to the setback zones, a Phase II Well Head Protection Area has been delineated. A Phase II WHPA also referred to as the recharge area, is the geographic area surrounding a well or well field providing potable water to a community water supply as modeled using computer software to determine the five-year time of travel.

To reduce the risk to the source water, Collinsville has implemented a Source Water Protection Plan, which includes proper abandonment of potential routes of groundwater contamination within the WHPA, management of potential sources of water contamination, correction of any sanitary defects that might be present at the treatment facility, and development of a comprehensive action plan in case of an emergency. In addition, the City of Collinsville conducts tours and programs to increase the public awareness of source water protection. The effort has resulted in the community water supply receiving a special exemption permit from the Environmental Protection Agency which allows a reduction in monitoring which reduces laboratory analysis costs.

2017 Regulated Contaminants Detected

Lead and Copper

Definitions:
 Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
 Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2017	1.3	1.3	0.0053	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Water Quality Test Results

Definitions:
 The following tables contain scientific terms and measures, some of which may require explanation.

Avg:
 Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:
 A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:
 A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:
 The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:
 The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:
 The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:
 The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na:
 not applicable.

mrem:
 millirems per year (a measure of radiation absorbed by the body)

Water Quality Test Results

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2017	1	0.8 - 1	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2017	5	3.81 - 5.41	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (THM)	2017	48	28.2 - 47.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	08/04/2015	1.3	1.3 - 1.3	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	08/04/2015	0.013	0.013 - 0.013	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	08/04/2015	0.811	0.811 - 0.811	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Nitrate [measured as Nitrogen] - Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall

or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Sodium 08/04/2015 26 26 - 26 ppm N Erosion from naturally occurring deposits. Used in water softener regeneration.

Radioactive Contaminants Collection Date Highest Level Detected Range of Levels Detected MCLG MCL Units Violation Likely Source of Contamination

Combined Radium 226/228 10/05/2016 1.176 1.176 - 1.176 0 5 pCi/L N Erosion of natural deposits.

Gross alpha excluding radon and uranium 10/05/2016 0.931 0.931 - 0.931 0 15 pCi/L N Erosion of natural deposits.